developing the crank case compression type two stroke cycle diesel engines.

6. Acknowledgement

The author warmly wishes to extend his thanks to Dr. K. Hatta, Dr. K. Asanuma and Dr. H. Tanaka, Tokyo University for their cordial instructions, and to Messrs. Y. Tanaka and M. Tamari, Kagoshima

University for their enthusiastic help in many ways.

References

- (1) S. Isigami, Y. Tanaka and M. Tamari: This Bulletin, p. 524.
- (2) K. Tomizuka and H. Sibata: *Report on Aeronautical Research Laboratory, Tokyo University*, No. 111 (1933), p. 673.

621.039.56:532.517

Hydraulic Instability in Boiling Water Reactors*

By Toshiro TERANO**, Kenji KUROSU***, Yujiro MURAYAMA***
and Yukiteru OKUMURA***

The hydraulic instability is one of the impermissible evils in the operation of BWR. And there has been no effective way of preventing it, because its mechanism is not clarified yet. The authors made many experiments with an electrically heated natural circulation loop which has electric condenser type void meters. As a result, they conclude that the hydraulic instability is a kind of non-linear oscillation caused by the combination of the fluid kinetics in the heated section and the non-linearity of the friction loss of the two-phase flow. They also derive analytically a block diagram of the circulation loop, in which the kinetics of fluid are simulated with simple linear transfer functions except the term of friction loss. The solutions, calculated by an analog computer, coincide well with the experimental results.

1. Introduction

The self balance ability in BWR is so strong that it can be operated without driving the control rods. On the other hand, the output is apt to oscillate and this is a serious problem for designing a stable reactor. There are two major causes of oscillation. The first is a physical one which depends on the feedback effect of void coefficient, and the second is a hydraulic one⁽⁸⁾ which comes from the kinetic behavior of the circulating water. These causes are mixed in the oscillation in real reactors. Though there have been many studies⁽¹⁾ on the first one, the mechanism of the second one is not yet clear and we have no definite way of preventing it. The authors have made many experiments by using an electrically heated natural circulation test loop and concluded that the hydraulic instability is a kind of nonlinear oscillation which is based on the non-

linearity of the pressure loss in the two-phase flow. Also they analyzed it by the simple feed-back theory.

2. Experimental equipment

If we neglect the void coefficient, the circulation in BWR can be simulated with an electrically heated natural circulation loop as represented by Fig. 2. The heated section is a glass tube which includes an iron rod. This rod is heated by D. C. current

Fig. 1 BWR

* Received 20th March, 1962.

** Professor, Tokyo Institute of Technology, Meguro-ku, Tokyo.

*** Research Associate, Transportation Technical Research Institute.

directly. The circulation water enters from the bottom, evaporates and goes up to a steam separator. And only the water goes down through the other pipe and circulates. Forced circulation also can be done when the circulating-pump loop is open. Sometimes we change the orifice inserted at the exit of the heated section or in the down-comer, therefore arbitrary friction coefficient can be chosen in any section.

The pressure is a very important factor in the hydraulic oscillation, but all experiments were made under the atmospheric pressure because the hydraulic instability happens more easily under the low pressure condition and it is more convenient for observation.

For measurement, a flow meter, a difference-pressure meter and many thermometers are employed. Especially, electrostatic capacity type void-meters are used in order to know the transient distribution of the void in the heated section. These void meters are checked with an air-water mixed two-phase flow system. The static characteristic of this meter is shown in Fig. 4. All measures are recorded by an oscillograph.

Heater length: 130 cm
Heater diameter: 8 mm
Glass tube inn. diameter: 20 mm
Down comer inn. diameter: 50 mm
Electric power source: D.C. 20 V, 16 000 A
Pump: centrifugal, 2 HP

Fig. 2 Experimental equipment

3. Experimental results

3.1 Natural circulation

In some natural circulating conditions, the periodic change of the circulating flow rate is observed. Fig. 5 is an example of this oscillation. The condition which causes hydraulic instability is rather complicated but the heating power and the subcool temperature are most effective. Fig. 6 shows the amplitude of the circulating flow rate as a function of inlet water temperature. We can see that the system is stable both when the subcool temperature is very low and when very high. The oscillation begins only when the inlet temperature is medium. If the heating power is increased, the unstable range is moved and widen. If the power is below a certain threshold, the system remains always stable.

Fig. 3 Void meter

Fig. 4 Characteristic of void meter

The system gets stable if the down-comer valve is throttled. On the other hand, it gets unstable when an orifice is inserted at the exit of the heating section.

The period of oscillation is almost 4 to 6 seconds and is not affected so much by the operating condition, except when the system is near the unstable limit.

3.2 Static characteristics

This system is always stable under forced circulation and the further tests seem unnecessary, but they are quite important to get the static characteristics near the equilibrium point in the natural circulation. In the static test, the measuring of the pressure drop through the loop and the buoyancy is most important. However, the direct measurement of buoyancy is so hard that the authors calculate it

from the static void distribution. One of such distributions is shown in Fig. 7. Fig. 8 is an example of the static characteristics. We can see that the friction loss curve has remarkable nonlinearity, especially when the subcool is large. In Fig. 8, the intersection of the friction loss curve and the buoyancy curve corresponds to the equilibrium point under natural circulation. However, in natural circulation, this point is not always stable but the flow rate oscillates around this point when the system is unstable.

Fig. 6 Amplitude inlet velocity

Fig. 7 Static void distribution

Fig. 5 Example of oscillation

The thick line in Fig. 8 shows the oscillating range of the inlet velocity under the natural circulation. It is clear that the amplitude of oscillation is over the linear range of the friction loss curve. The amplitude also exceeds the linear range of the buoyancy curve but this is not so wide as in the friction loss.

The static characteristics are affected by the heating power but the shape of the curves do not change remarkably. On the other side, we should

Fig. 8 Static characteristics

Fig. 9 Step response of void

mark the fact that it changes considerably even though the subcool temperature changes little.

3.3 Kinetics

The kinetics of a two-phase flow has not been studied enough. Fig. 9 is an example of the dynamic response of void fraction by the stepwise change of the heat flux and the inlet flow rate. These responses are so noisy that it is hard to get transient curves precisely. However, concerning the analysis of hydraulic instability, we do not need an exact knowledge about the response curve but the approximate time constants of responses will be sufficient as explained later. According to the experimental results, the time constant in the boiling region is nearly equal to the flow time of bubble (about one second).

4. Analysis

The natural circulating loop is now simulated with a simple model as Fig. 10. And we assume that (1) the pressure is constant and uniform, (2) the heat flux is also constant and uniform along the tube length, (3) the void is distributed uniformly in the radial direction and (4) the effect of upper reflector on the circulation is negligible.

The following relation is always satisfied in any natural circulation system:

$$\frac{d}{dt} (\text{total momentum of circulating flow}) = (\text{buoyancy}) - (\text{friction loss}) \quad \dots\dots (1)$$

This equation includes the kinetics of a two-phase flow and is very hard to solve exactly⁽²⁾⁽³⁾⁽⁴⁾. Dr. J. A. Fleck analyzed it⁽³⁾, supposing that there is no riser and no subcool, and concluded that the hydraulic instability is caused by the nonlinearity of the momentum term. Mrs. S. Levy and E.S. Beckjord⁽²⁾ concluded contrarily that the major cause of instability is in the first term of the right side of Eq. (1).

Fig. 10 Model of natural circulation

However, the above-mentioned experimental results show us that the nonlinearity of these terms is not so large as to influence the stability of circulation. However, the term of friction loss changes sensitively according to its parameter change. For instance, the sign of the slope of friction loss becomes minus for some inlet velocity. Consequently, it seems the best way to approximate the terms of momentum and buoyancy with linear functions, and only the friction loss term is treated as a nonlinear function.

4.1 Kinetics of each section

Since the kinetics of a two-phase flow is quite different from that of a single-phase one, it is convenient to separate the whole system into several sections as shown in Fig. 10 and to get the transfer function for each section. Even the linearized transfer function of the heated section is still very much complicated⁽⁷⁾, but its essential quality is not missed by the approximation with single capacity time lag. Especially, the transfer function in the boiling section, of which kinetics includes many problems, can be approximated enough with such simple lag, because its response is very fast compared with the oscillating period.

The following nomenclature is used.

L :	co-ordinate along the channel	cm
L_w :	length of non-boiling region	"
L_b :	length of boiling region	"
L_c :	length of heating section = $L_w + L_b$	"
L_r :	length of riser	"
A_c :	sectional area of channel	"
A_d :	sectional area of down comer	"
T_w :	flow time through L_w	sec
T_b :	flow time of void through L_b	"
T_r :	flow time of void through L_r	"
T_m :	time constant of fluid acceleration	"
T_n :	time constant of nuclear reaction	"
T_f :	time constant of fuel rod	"
M_w :	momentum of circulating water for unit sectional area	g/cm sec
M_b :	momentum of two-phase flow in L_b for unit sectional area	"
M_r :	momentum of two-phase flow in L_r for unit sectional area	"
t :	time	sec
s :	operator = d/dt	sec ⁻¹
g :	gravity constant	cm/sec ²
R :	heat flow for unit length of channel	cal/sec cm
I :	enthalpy of fluid	cal/g
V :	velocity of water in heating section	cm/sec
F_e :	void fraction at channel exit	
X_e :	steam quality at channel exit	

$\bar{F}$:	mean void fraction in channel	
$\bar{F}_r$:	mean void fraction in riser	
ΔP :	pressure drop through loop	g/cm sec ²
H :	buoyancy in natural circulation	"
H_p :	circulating force by circulating pump	"
E :	buoyancy ratio between riser and channel	
ρ_0 :	density of water	g/cm ³
ρ_s :	density of saturated steam	"
γ :	slip ratio	
k_1 :	gain constant of friction loss in linear range	
k_2 :	gain constant of friction loss in non-linear range	
k_3 :	gain constant of pump characteristics	
k_4 :	dimensionless void coefficient	
K :	non-linear gain of friction loss	
κ :	gain constant of prompt neutron	

The variables written in capital mean the initial values when the system is in equilibrium condition. And small letters mean the dimensionless deviations from the initial values. For example, $v = \Delta V/V$, where ΔV is the deviation and V is the initial value. Suffices i and e express the value at the entrance and the exit of channel respectively.

The transfer function in each section can be approximated as follows (see Appendix).

Non-boiling section:

$$l_w = \frac{1}{T_w s + 1} (v_i - r) \dots\dots\dots (2)$$

Boiling section:

$$X_e = \frac{1}{T_b s + 1} (r - v_i + l_b) \dots\dots\dots (3)$$

$$f_e = \frac{1 - F_e}{1 - X_e} \cdot x_e \dots\dots\dots (4)$$

$$\bar{f} = f_e + \frac{1}{T_b s + 1} \cdot l_b \dots\dots\dots (5)$$

$$l_b = \frac{-L_w}{L_b} \cdot l_w \dots\dots\dots (6)$$

Riser section:

$$\bar{f}_e = \frac{1}{T_r s + 1} \cdot f_e \dots\dots\dots (7)$$

Buoyancy:

$$h = (1 - E) \cdot \bar{f} + E \cdot \bar{f}_r \dots\dots\dots (8)$$

Acceleration:

$$h - \Delta p = T_m s \cdot v_i \dots\dots\dots (9)$$

Furthermore, there is a non-linear relation between v_i and Δp . This relation is considered as follows. If we suppose that the static characteristic is as Fig. 11, and the initial inlet velocity is V_i , the total pressure drop ΔP is the sum of ΔP_b (the pressure drop in the two-phase flow region) and ΔP_w , (that in single-phase flow region). If V_i changes stepwise to V_i' , ΔP_w changes to $\Delta P_w'$ at once along

the line on which L_w is constant. The outlet void fractions F_e and ΔP_b also change to F_e' and $\Delta P_b'$ respectively, but are accompanied with time lag of which the time constants are T_b and T_r as seen in Eqs. (3), (4) and (7). Though we supposed that L_w is constant in the above discussion, L_w really changes slowly to L_w' according to Eq. (2). Therefore, $\Delta P_w'$ and $\Delta P_b'$ are not, but $\Delta P_w''$ and $\Delta P_b''$ are the last equilibrium values. However, the difference between $\Delta P_b'$ and $\Delta P_b''$ is so small that we can neglect the effect of L_w . As the result, the transfer function of the pressure drop is as follows.

Pressure drop:

$$\delta p = k_1 + \frac{K}{(T_b s + 1)(T_r s + 1)} \cdot v_i \quad (10)$$

In Eq. (10), k_1 is the coefficient which expresses the effect of δp_w and K is a non-linear function which expresses the effect of δp_b . We approximate now the characteristic of the pressure drop with a broken line as Fig. 12 (a), of which the positive slope region has the same inclination. Moreover, assuming the constant L_w line is parallel to the $F_e = 0$ line, Fig. 12 (a) can be divided as Fig. 12 (b). Each slope of linear and non-linear region are equal to the gain

Fig. 11 Time lag of ΔP

Fig. 12 Approximate pressure drop curve

constants of the water region and of the boiling region respectively.

4.2 Block diagram

Combining the transfer functions of respective sections together, we get the block diagram of the whole circulating system as Fig. 13. The double box in Fig. 13 is the normalized static characteristic of non-linear pressure drop in Fig. 12 (b). All dynamic characteristics, such as the stability limit, the period, the amplitude, can be calculated from Fig. 13. If the major purpose of study is to get the criterion of stability, we need not consider the non-linearity but only k_1 and k_2 . The describing function method is convenient for studying the details of the oscillation. The describing function of such negative saturated function is always negative as shown in Fig. 14. If we plot this describing function and the vector locus of the linear part together on s -plane, their intersection indicates a stable limit cycle, that is, hydraulic instability.

It is necessary for the existence of a limit cycle that the vector locus has an advanced phase at low frequency and also the negative slope k_2 is large enough. The fact that the intersection exists at low

Fig. 13 Block diagram

Fig. 14 Describing function of negative saturation

frequency range quite agrees with the experimental results that the period of hydraulic instability is considerably long compared with the time constants of each section.

4.3 Analog computing results

The block diagram (Fig. 13) is analyzed by an analog computer, because the accuracy of the amplitude calculated by the describing function method is not good. An example of this analysis is shown in Fig. 16, where the wave-form and phase of calculation quite agree with experiment. Fig. 17 shows the amplitude of inlet velocity and its period as functions of the inlet temperature. Both the calculation and the experiment coincide well. In these calculations, they used the experimental values as many constants, except time constants which were estimated theoretically.

In the analysis of the analog computer, the small variation of time constants does not influence so much the stability but the system is very sensitive for k_1 , k_2 . Fig. 18 is the relation between the unstable range and the combination of k_1 and k_2 . The

system is always stable when the non-linear gain k_2 is small, but runs away if k_2 is too large. When the linear gain k_1 is too large, the system is also stable or runs away but never oscillates.

Above mentioned computing results are now compared with the experimental results. As mentioned in Sec. 3.1, it is stable whether the inlet temperature is too low or too high. This is explained as follows. The slope of the pressure drop curve near the equilibrium point becomes positive as shown in Fig. 8, when the subcool is too small or too large. Then k_2 is very small and the system is stable.

The reason why it becomes stable as the down comer is throttled is that the positive slope of pressure drop increases and k_1 too, so it falls into stable range. On the contrary, it is because of an increase of k_2 that the system becomes unstable if an orifice is inserted at the exit of the channel. When the sectional area of channel is small, both k_1 and k_2 are small, but in our equipment it gets rather unstable. Perhaps, the effect of k_2 is greater than k_1 .

The above results are obtained by assuming

that the nonlinearity is symmetric around the equilibrium point. However, the variation of the inlet velocity sometimes includes only one break point. In such a case, the nonlinearity is unsymmetric. We analyzed some of these cases, but the results are not so different from those of the symmetrical case.

4.4 Forced circulation

The kinetics of the heating section is not changed even if forced circulation is adopted. However, a feedback loop is added because of the flow characteristic of the circulating pump. If we suppose the pump characteristic as Fig. 20 and linearize it around the working point, we get

$$h_p = -k_3 v_i \quad \dots\dots\dots(11)$$

where h_p is the circulating force by a pump and k_3 is a constant of the pump characteristic. In this case, the total circulating force in the loop is equal to the sum of h and h_p . And Fig. 13 should be redrawn so as to add a feedback loop, of which the gain constant is k_3 , parallel to the loop of k_1 . Since this addition makes k_1 larger, we can expect easily that the system gets more stable.

4.5 Consideration of void coefficient

We neglected the effect of void coefficient before now, but in BWR the heat generation changes in proportion to the mean void $\bar{F}$. This relation can be expressed approximately by the following equation.

$$r = -\frac{k_4(\kappa T_n s + 1)}{T_f s(T_f s + 1)} \bar{F} \quad \dots\dots\dots(12)$$

where T_n and T_f are the time constants of delayed neutron and fuel rod respectively, and k_4 is the void-

Fig. 19 Unsymmetrical friction loss

Fig. 20 Pump characteristic

coefficient and κ is a constant of prompt neutron.

The block diagram in this case is shown in Fig. 21. The vector locus of the linear section always has positive phase at low frequency and the intersection of the describing function has also a little advanced phase compared with Fig. 15. Therefore, it may be considered that the period is shorter and the system is more stable because of the reduction of the open loop gain. However, the results by the analog computer is almost the same as the case when the void coefficient is neglected.

5. Conclusion

The phenomenon of hydraulic instability can be explained by the non-linear feed-back theory and the calculation agrees well with the experimental results. Besides, we may consider the instability of a two-phase flow itself or the effect of the upper reflector as the causes of the oscillation in the circulating loop. However, these effects are not so large that they may be major causes of the hydraulic instability in a power reactor.

The authors don't mention the effect of pressure but it will be easily estimated from the calculation, that is to say, the density of steam increases and the buoyancy, slip ratio and the pressure drop decrease, therefore it gets stable when the pressure is increased. Any effects of other parameters may be estimated by this analysis, but the only problem is that there is no way of calculating the pressure drop of a two-phase flow exactly. In this paper, all the experimental curves are used as the static characteristic of pressure drop.

Appendix I Transfer function in non-boiling heated section

According to the assumption in Chapt. 4, we get the following equations for the heat- and matter-balance.

$$R = A_c \rho \left(v \frac{\partial I}{\partial L} + \frac{\partial I}{\partial t} \right) \quad \dots\dots\dots(13)$$

Fig. 21 Feedback by void coefficient

$$\frac{\partial(\rho V)}{\partial L} = -\frac{\partial \rho}{\partial t} \quad \text{.....(14)}$$

where the side capacity effect of channel is neglected.

Since $\rho = \rho_0$ (const.), $V = V_i$ in the non-boiling heated section, we can linearize the above equations by considering the small deviation from the initial equilibrium condition. Solving them, the exit enthalpy of the non-boiling heated section is

$$i_e = \frac{1 - e^{-T_w s}}{T_w s} (r - v_i) + e^{-T_w s} i_i \quad \text{.....(15)}$$

where T_w is the flow time in which the fluid goes through L_w .

$$T_w = L_w / V_i \quad \text{.....(16)}$$

The variation of the non-boiling section ΔL_w is proportional to that of the exit enthalpy ΔI_e but the sign is opposite. So we get

$$l_w = -i_e \quad \text{.....(17)}$$

The step response of l_w is shown in Fig. 23.

Appendix II Transfer function in boiling section

The transfer function in boiling section can't be written with a simple form⁽⁶⁾, because the velocity of water and steam is different. But, as explained before, we don't need so exact solution, and therefore the velocity slip can be neglected. Then, Eqs. (13) and (14) hold as well in the boiling section. In this case, ρ is the density of the mixture of water and steam and is in inverse proportion to the enthalpy I . Solving Eqs. (13), (14) after linearizing them⁽⁷⁾, we get

Fig. 22 Non-boiling section

Fig. 23 Step response of L_w

$$i_e = \frac{\rho_s}{\rho_0 - \rho_s} \frac{1 - (V_e/V_i)e^{-T_b s}}{T_b s - \ln(V_e/V_i)} \ln\left(\frac{V_e}{V_i}\right)(r - v_i) + \left[1 - \frac{T_b s}{T_b s - \ln(V_e/V_i)} \left\{1 - \frac{V_e}{V_i} e^{-T_b s}\right\}\right] l_b \quad \text{.....(18)}$$

where T_b is the flow time in the boiling section and is

$$T_b = \frac{L_b}{V_e - V_i} \ln\left(\frac{V_e}{V_i}\right) \quad \text{.....(19)}$$

T_b agrees with the flow time which is calculated by Dr. Fleck's method⁽⁸⁾, assuming that the velocity distribution is linear.

There is a simple relation between the enthalpy deviation i and the steam quality deviation x as follows.

$$i_e = x_e \quad \text{.....(20)}$$

The step response of x_e obtained from Eqs. (18), (20) is shown in Fig. 24. Though the shapes of step responses in Fig. 23 and 24 are quite different, their settling times are same in that they are equal to the flow time. Therefore, there is not so big error for the whole system, even if we approximate the transfer function in the heating section with a single capacity lag of which the time constant is equal to the flow time. When the slip ratio is controversial, we had better use the void flow time⁽⁶⁾ as the time constant.

From Eqs. (15), (17), (18) and (20), we get Eqs. (2) and (3). Eqs. (4) and (6) are easily derived from the static relation.

The mean void $\bar{F}$ is influenced by both the exit void F_e and the boiling length L_b as Fig. 25. If we

Fig. 24 Step response of x_e

Fig. 25 Variation of mean void

suppose the void distribution is linear, the variation of mean void is expressed by the area of double oblique lines in it.

$$\bar{f} = 1 - \frac{(F_e - \Delta F_e)(L_b - \Delta L_b)}{F_e L_b} = f_e + l_b \quad \dots\dots(21)$$

This equation exists only in the static condition.

If we consider the time lag, Eq. (21) is rewritten as Eq. (5), because there is time lag T_b between the exit steam condition and the boiling length as Eq. (3).

Appendix III Transfer function in riser

There is also a two-phase flow in the riser section. However, void distribution in it is uniform and the mean void $\bar{F}_r$ is equal to F_e , because it is not heated. When F_e changes stepwise, it takes T_r sec until the response of $\bar{F}_r$ settles in the same way as in the boiling section. Approximating this time lag with a single capacity lag, we get Eq. (7).

Appendix IV Transfer function of circulating force

The circulating force is determined by the mean void in the boiling and riser section.

$$H = (\bar{F}L_b + \bar{F}_r L_r) \rho_0 g \quad \dots\dots(22)$$

Linearizing and making dimensionless Eq. (22), we get

$$h = (1 - E) \cdot \bar{f} + E \cdot \bar{f}_r \quad \dots\dots(8)$$

where

$$E = \frac{\bar{F}_r L_r}{\bar{F}L_b + \bar{F}_r L_r} \quad \dots\dots(24)$$

Appendix V Transfer function of acceleration

There is the following relation among the total momentum of fluid M circulating force H and the pressure drop P .

$$\frac{dM}{dt} = H - \Delta P \quad \dots\dots(25)$$

The momentum in each section is now calculated⁽³⁾ based on the inlet velocity.

Down comer:

$$M_d = (L_e + L_r) \frac{A_e}{A_d} \cdot \rho_0 V_i \quad \dots\dots(26)$$

Non-boiling region:

$$M_w = L_w \rho_0 V_i \quad \dots\dots(27)$$

We suppose the void distribution is linear in the two-phase flow region.

Boiling region:

$$M_b = L_b \left[V_i \left\{ \frac{F_e}{6} (\rho_s \gamma - \rho_0) + \frac{\rho_0}{2} \right\} + V_e \left\{ \frac{F_e}{3} (\rho_s \gamma - \rho_0) + \frac{\rho_0}{2} \right\} \right] \quad \dots\dots(28)$$

Riser:

$$M_r = L_r \left\{ F_e \gamma \rho_s + (1 - F_e) \rho_0 \right\} \frac{A_e}{A_r} \cdot V_e \quad \dots\dots(29)$$

If we suppose the water velocity at the exit of channel is proportional to the inlet velocity V_i , the total momentum $M (= \sum_n M_n)$ is in proportion to V_i .

So we get the relation between m and V_i .

$$m = \frac{\Delta M}{M} = \frac{\Delta V_i}{V_i} = v_i \quad \dots\dots(30)$$

On the other side, Eq. (25) is linearized as follows.

$$T_m \frac{dm}{dt} = h - \delta p \quad \dots\dots(31)$$

where T_m is the time constant of the fluid acceleration.

$$T_m = \frac{M}{H} \quad \dots\dots(32)$$

Laplace transformation of Eq. (31) is Eq. (9).

References

- (1) T. Terano: *Preprint for 1st National Conf. of Atomic Power*, (1952).
- (2) S. Levy and E. S. Beckjord: *ASME Paper*, 60-HT-27.
- (3) J. A. Fleck: *Nuclear Energy-A*, (1960), p. 114.
- (4) E. R. Quandt: *4th National Heat Transfer Conf.*, (1960).
- (5) S. Oki and others: *Jour. Japan Soc. Mech. Engrs.*, Vol. 64, No. 508 (1961), p. 736.
- (6) T. Kawai and others: *Atom. Energ. Soc. Japan*, Vol. 3, No. 3 (1961), p. 168.
- (7) T. Terano: *Trans. Tech. Res. Inst. Report*, Vol. 7, No. 10 (1957), p. 1.