Fig. 2 : C-H-O ternary diagram with a carbon deposition boundary at 1073, 973, and 873 K and 1 atm

Fig.3 : The SOFC cell temperature profiles for different air-steam mixtures as SOFC reforming agents

efficiencies ($\eta_{\text{SOFC}}=72.3\%$). It should be noted, however, that a high exhaust gas temperature is favorable for hybrid operation. The efficiencies of the direct-biogas SOFC-MGT hybrid CHP system versus air-steam mixtures as reforming agents are depicted in Fig. 4. Increasing the amount of air into fuel channel decreases the SOFC efficiency (η_{SOFC}), while the exhaust heat from SOFC increases. As a result, the variation of air-steam mixtures shows moderate effects on the system electrical ($\eta_{\text{ele,sys}}$) and the system CHP efficiencies (η_{CHP}). With the increase of air addition, TER is increased from 0.38 to 0.41 due to higher heat energy in the SOFC off-gases going to MGT system leading to reduction in additional fuel fed to the burner. The $P_{\text{MGT}}/P_{\text{SOFC}}$ is increased from 0.37 to 0.40 when the air to biogas ratio of 0.4 is introduced. Figure 5 illustrates the influence of U_f on SOFC and system performance when steam-to-carbon ratio is fixed at 2.0. The study shows that, by varying U_f from 0.65 to 0.90, η_{SOFC} increases monotonously from 42.3 to 59.8%. Owing to a considerable increase in η_{SOFC} , $P_{\text{MGT}}/P_{\text{SOFC}}$ drops from 0.41 to 0.36. When U_f increases, unused fuel from the anode exhaust decreases and consequently more additional fuel is needed to maintain the set TIT. This results in a small change in $\eta_{\text{ele,sys}}$ and an increase of TER.

4. Conclusions

Analytical results mainly indicate that:

1. Considering individual direct-biogas SOFC operation, the

Fig.4 : The influence of air-steam mixtures as reforming agents on system performance.

Fig.5 : The influence of fuel utilization factor on system performance.

presence of oxygen shows negative impacts on the SOFC performance as well as aggravates temperature stress near the stack inlet

2. Adding air to biogas raises the stack operating temperature leads to an increase in useful heat output as well as the electrical power production of MGT, and as a consequence, compensates for $\eta_{\text{ele,sys}}$ drop.
3. In the system studied, η_{SOFC} and η_{CHP} are directly proportional to U_f ; however, $\eta_{\text{ele,sys}}$ is adversely affected by the increase of U_f , mainly due heat balance between the stacks and MGT.

Acknowledgements

This work was partially supported by NEDO, under the Development of System and Elemental Technology on SOFC Project.

References

- [1] Wongchanapai S., Iwai H., Saito M. and Yoshida H., Performance evaluation of a direct-biogas solid oxide fuel cell-micro gas turbine (SOFC-MGT) hybrid combined heat and power (CHP) system. J. Power Sources 223(2013), pp 9–17.
- [2] Wongchanapai S., Iwai H., Saito M. and Yoshida H., Selection of suitable operating conditions for Planar Anode-supported Direct-internal-reforming Solid-Oxide Fuel Cell. J. Power Sources 204(2012), pp 14–24.
- [3] Kotas, T.J., The Exergy Method of Thermal Plant Analysis, 2-nd edition, Krieger Publishing Company, USA. (1995)